

## County of San Diego Department of Planning and Land Use BUILDING DIVISION

## ACCESSIBILITY CORRECTION LIST

Public Accommodations & Commercial Buildings

14B<sup>4</sup>

Hospital, Long-Term Care, and Rehabilitation Occupancies/Uses

| PLAN CHECK NUMBER: |  |   | OWNER: |   |  |
|--------------------|--|---|--------|---|--|
| GEI<br>1.          | Specific occupancy-related accessibility provisions may modify general requirements but never at the exclusion of them.  CBC 1103B.1  Regardless of occupancy classification per CBC Chapter 3, health-care-related accessibility provisions apply to any portion of a facility with a health-care use.  CBC 1103B.1 |   | 6.     | following:  In general purpose hospitals, at least 10 percent of patient bedrooms and toilet rooms shall meet accessibility provisions of items 7 and 8  In long-term care facilities, at least 50 percent of patient bedrooms and toilet rooms shall meet accessibility provisions of items 7 and 8  In hospitals and rehabilitation facilities specializing in treatment of mobility conditions, all patient bedrooms and toilet rooms shall meet accessibility provisions of items 7 and 8 |  |
| <b>3</b> .         | At medical facilities where persons may need assistate responding to an emergency and periods of stay may hours, provide at least one accessible entrance complete following:  Protected from weather by canopy or roof overful including passenger drop-off/loading zone per a correction list 2B                   | y exceed 24 plying with the nang accessibility  CBC 1109B.2 | 7.     | <ul> <li>CBC 1109B.3(1), CBC 1109B.3(2), and CBC 1109B.3(3)</li> <li>7. Specify and dimension the following at each accessible patient bedroom:  <ul> <li>Minimum 60-inch-diameter turnaround space or equivalent T-shaped space (preferably between beds in rooms with multiple beds)</li> <li>Minimum 36-inch-wide clear floor space along each side of each bed</li> <li>Entry door per accessibility correction list 6B</li> </ul> </li> </ul>  |  |
| +.                 | All public- and common-use areas shall be accessible.  Provide accessible diagnostic and treatment areas.  | cBC 1109B.3   | 8.     | CBC 1109B.4  Accessible patient toilet rooms shall comply with accessibility  |  |
| ADI                | DITIONAL REQUIREMENTS  | CBC 1109B.6   |        | correction list 9B, while associated bathing facilities shall comply with accessibility correction list 10B.  CBC 1109B.5   |  |
|                    |  |   |        |   |  |
|                    |  |   |        |   |  |
|                    |  |   |        |   |  |
|                    |  |   |        |   |  |
|                    |  |   |        |   |  |
|                    |  |   |        |   |  |
|                    |  |   |        |   |  |

THIS DOCUMENT IS FOR PLAN REVIEW ONLY.

CORRECTION LIST ITEMS MAY NOT BE REPRODUCED OR COPIED ON PLANS.

PROVIDE COMPLETE DETAILS, DIMENSIONS, AND NOTES TO SATISFY CORRECTION ITEMS.